

DENTAL AIR SYSTEM

Installation and Operation Manual







TABLE OF CONTENTS

Section	<u>Page</u>
Safety Instructions.	2
Congratulations	3
Purpose of this Manual	3
Sizing Guide	3
Key Parts Identification	4
Supplied Components	5
Site Requirements	6
Installation Information	8
Tandem Compressor Setup	. 10
Touch Screen Controls	. 12
Operating Information	. 17
Troubleshooting	. 18
Maintenance	. 20
Replacement Parts	. 22
Optional Accessories	. 23
Product Specifications	. 24
Warranty	. 25
On-Line Warranty Registration.	. 25

SAFETY INSTRUCTIONS

Use of the **AirStar NEO-INT** not in conformance with the instructions specified in this manual may result in permanent failure of the unit. AirStar systems are to be used by certified trained dealer technicians or qualified Air Techniques personnel.

WARNING: To prevent fire or electrical shock, do not expose this

equipment to rain in or moisture.

All user serviceable items are described in the maintenance section. Manufacturing date code on serial number label is in the format Month YYYY.

ATTENTION USERS:



Alerts users to important Operating and Maintenance instructions. Read carefully to avoid any problems.



Warns users that uninsulated voltage within the unit may be of sufficient magnitude to cause electric shock.



Indicates the ON and OFF position for the Equipment power switch.



Warns users of hot surfaces. There is a danger of burns. Work near these surfaces only after they have cooled down.



MEDICAL ELECTRICAL EQUIPMENT

WITH RESPECT TO ELECTRICAL SHOCK, FIRE, MECHANICAL AND OTHER SPECIFIED HAZARDS ONLY IN ACCORDANCE WITH UL-60601-1, CAN/CSA C22.2 NO.601.1 66CA



Indicates protective Earth Ground for the Equipment power switch.



Air Techniques, Inc. 1295 Walt Whitman Road Melville, New York, USA 11747- 3062

CONGRATULATIONS

Congratulations on your purchase of **AirStar NEO-INT**, the latest addition to the AirStar family of dental air systems from Air Techniques. The six available models listed below by the sizing guide chart are specifically designed for international use. **AirStar NEO-INT** is referred to as **AirStar NEO** throughout this manual.

The **AirStar NEO** series combines Air Techniques' exclusive Membrane Dryer technology and new integrated diagnostic monitoring functions for a state-of-the-art dental air compressor. Air is quadruple filtered by the Membrane Dryer to ensure it is the cleanest and driest possible. The intelligent controls features a full color, digital Touch Screen Display, providing trouble-free performance by allowing easy accessibility to user settings and setup controls. The system continuously monitors itself and delivers diagnostic controls keeping you informed of preventative maintenance with "smart alarms".

Your **AirStar NEO** generates 100% oil-less, ultra-dry dental air which protects valuable handpieces from premature failure due to the effects of moist air and the build-up of oil residue. Because no oil is used for mechanical lubrication, there is no chance of introducing an oily film to a prepared surface which could compromise resin retention and restorations, wasting chair time. Most important, your patient's health is protected with ultra-dry air that provides an environment that is not conducive to bacterial growth.

The **AirStar NEO** utilizes a long stroke, small bore piston to compress the air. This piston is bonded with an anti-friction polymer to eliminate the need for oil. The air is forced through the Membrane Dryer system consisting of the cooler and the membrane. This system removes moisture and air impurities providing the driest possible compressed air while maximizing performance. This 100% ultra-dry air is reserved in the main storage tank for use by the operatory air system.

The AirStar NEO features include:

Low pressure dew point

- Compact size for space-saving installation
- Virtually Maintenance Free
- Uninterrupted compressor availability
- Maximum dryness with quadruple filtered air
- Intelligent controls for trouble-free performance

PURPOSE OF THIS MANUAL

This manual provides installation, operation and maintenance instructions for the support of the six available **AirStar NEO** Dental Air System international models shown below by the sizing guide chart. Review and follow the guidelines included in this manual to ensure that the system provides the highest level of service.


SIZING GUIDE

Choosing the correct size **AirStar NEO** for your practice depends on the number of air users and the anticipated air demand. To assure optimum compressor operation, the air demands should not exceed the number of air handpiece users shown in the chart below:

Model Description	AS12NEO-INT	AS22NEO-INT	AS30NEO-INT	AS40NEO-INT	AS50NEO-INT	AS70NEO-INT
Recommended Number of Users	1 - 2	2 - 3	3 - 4	4 - 5	5 - 7	7 -1 0
Number of Motors	1	1	2	2	2	3



KEY PARTS IDENTIFICATION





SUPPLIED COMPONENTS

Each **Airstar NEO** is shipped in a single carton containing the fully assembled unit and associated accessory kit. See Figure 1. Unpack and inspect for physical damage such as scratched panels, damaged components, etc. If any damage is found, notify Air Techniques so corrective action can be taken. Verify that all items were received.

The accessory kits, P/N 87478 and P/N 87479, shown below, contain identical components except for the length of 10mm Polyurethane Tube (items 9 & 10, P/N 54509). Kit P/N 87478, provides a tube 6 feet long (item 6) for use with five NEO-INT models, AS12NEO-INT through AS50NEO-INT. Kit P/N 87479, provides a tube 12 feet long (item 10) for use with model AS70NEO-INT only.

Item	Part Number	Description	Qty
1	87199INT	Installation and Operation Manual	1
2	9922-189	Web Warranty Registration	1
3	58017R-1	Bushing PCONN, 1/2 MNPT X 3/8 FNPT	1
4	87168	5 Micron Filter, 3/8" NPT	1
5	87169	6-Foot Hose, 3/8" ID, 3/8" MNPT x 3/8	1
6	87186	Close Nipple PCONN, 3/8" MPT	1
7	86394	Instructions for Airstar Filter Kit	1
8	87376	Leveling Foot Kit	1
9	54509	6-Foot, 10mm Polyurethane Tube (Included in kit, P/N 87478, for use with models AS10NEO-INT through AS50NEO-INT.)	6ft
10	54509 (See Note 1)	12-Foot, 10mm Polyurethane Tube (Included in kit, P/N 87479, for use with model AS70NEO-INT only.)	12ft
11	57662	Cleanstream Business Reply Card	1
12	31929	Reducing Coupling PCONN, 1/2 FNPT X 3/8 FNPT	1
13	87107	Instructions for Drain Tube	1
14	31931	Plastic Bucket, 3 x 5 x 3	1
15	53202-1 (See Note 2)	Push Button Panel Switch with Bi Color LED Indica- tor, 6 VDC	1

Airstar NEO Accessory Kits, Part Numbers 87478 and 87479

- **Note 1:** The additional 6-foot length (12 feet total) of the 10mm Polyurethane Tube is necessary to provide a drain tube for the second Dryer Membrane required on AS70NEO-INT models.
- **Note 2:** The 6VDC switch (P/N 53202-1) provided in accessory kit replaces the 24 VDC remote switch of the Remote Control Panel Kit as necessary to meet facility requirements. See Optional Accessories listed in this manual.

SITE REQUIREMENTS

	1					
Description Model	AS12NEO-INT	AS22NEO-INT	AS30NEO-INT	AS40NEO-INT	AS50NEO-INT	AS70NEO-INT
Nominal Supply Voltage (VAC, See Note)	220	220	220	220	220	220
Frequency (Hz)	50	50	50	50	50	50
Maximum Current (Amps)	3.7	6.5	7.4	10.2	13	19.5
Minimum Panel Breaker Rating (Amps)	20	20	20	20	20	30
Minimum Wire Size (AWG)	12	12	12	12	12	10
Note: Install a buck or boost transformer if service is above or below these ratings						


Site Electrical Requirements


Note: Install a buck or boost transformer if service is above or below these ratings				
Service Clearance:	Allow 12" on all sides for all models.			
Ambient Temperature:	Must not exceed 40°C (105°F)			
Air System Plumbing Connection:	3/8" F.N.P.T. Shut-off valve and a 6 ft. pressure hose (supplied)			
	Air distribution piping for all models - 1/2", type "L" or type "K" copper			
	If pipe volume is too great, more than 3.85L (235 in ³) or more than 30.5m (100 ft.) of 1/2" diame- ter pipe, a pressure regulator should be installed between the main tank and the distribution pip- ing and pressure set at 80 PSI.			
Environmental, Operating:	Indoor use at altitudes up to 2000m (6562ft.) Temperature 5 to 40°C (41 to 105°F). Supply voltage fluctuation of +/- 10% of nominal voltage.			
Environmental, Storage and Transport:	Temperature, -18 to 65°C (0 to 150°F). Relative Humidity, 0 to 90%.			
IEC 60601-1 Classification:				
Protection against electric shock (6.2):	Class I			
Applied Parts: (5.9.1, 8.3):	There are no Applied Parts.			
Protection against harmful ingress of water (6.3):	Ordinary, IPXO			
Degree of safety in the presence of flammable anesthetics mixture with air or with oxygen or with				
nitrous oxide (11.4, 11.5):	Not suitable.			
Mode of operation (6.6):	50% Duty Cycle; Maximum Continuous ON Time of 20 Minutes.			

AIRSTAR NEO AS12NE

AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

SITE REQUIREMENTS





INSTALLATION INFORMATION

AirStar NEOs are installed by authorized Air Techniques dealer service technicians. Please review these installation guidelines to make sure that your **AirStar NEO** will work to capacity for your office. (See Site Requirements, pages 6 and 7)

- Your AirStar NEO should be installed in a well ventilated area, with at least 12 inch clearance on each side for service access and to prevent overheating during high demand periods. If other equipment is located in the vicinity, the ambient temperature of the area must not exceed 105°F.
- The installation site should be clean and dry to prevent the air intake filters from clogging. If there is a concern about the quality of air where the AirStar NEO is placed, we recommend an optional Remote Air Intake (See Optional Accessories, page 23) which allows the compressor to intake clean air from a remote location.
- Air distribution piping for all models should be 1/2", type "L" or type "K" copper.
- PLUMBING CONNECTION: The Tank Outlet Assembly (See Figure 1, View C), (the storage tank outlet for the dry air) is connected to the operatory air system via a 3/8" F.N.P.T. shut-off valve and 6 foot length of pressure hose (supplied).

Note: If voltage is higher than 242V, install a bucking transformer.

- MINIMUM VOLTAGE: The minimum voltage is 198 Volts. Install a boost transformer if the service is below this rating.
- WIRING REQUIREMENTS: To help prevent fire, electric shock, injury, or death, the wiring and grounding must conform to the latest edition of the National Electrical Code, ANSI/ NFPA 70 and all applicable local regulations. Please contact a qualified electrician to check your wiring and breakers/fuses to ensure that there is adequate electrical power to operate the AirStar NEO.
- EQUIPMENT GROUNDING: All AirStar NEOs must be connected to a grounded metal, permanent wiring system, or an equipment grounding conductor must be run with the circuit conductors and connected to the equipment grounding lead in the AirStar NEO's flexible metal conduit power supply. Failure to do so can result in fire, electric shock, injury, or death. See Figure 2, Overall Site Requirements, page 7.
- ELECTRICAL POWER CONNECTION: All systems are shipped with open electrical connections and are directly connected to the branch supply circuit as shown by Figure 3. See Site Electrical Requirements, page 6, for the required branch circuit size for each system.



AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

INSTALLATION INFORMATION

Important: Each system should have a dedicated circuit panel.



All systems must be wired directly from an electrical box that complies with local electrical codes.



Remove all power to the system prior to working with electrical circuits. Contacting high voltage can cause serious injury or even death.




Figure 3. Electrical Connection Box

POST INSTALLATION CHECK

Make Sure Everything Is Running Properly

After your **AirStar NEO** has been installed and before it is put into operation, be sure to follow the check-out procedure detailed below:

- Check that Intake Filter(s) are fully seated into the compressor head(s) and that the Tank Outlet Valve is closed.
- Turn on the electricity. Check that the supply voltage remains above the minimum defined in the Site Requirements section while the AirStar NEO is running. If the supply voltage drops below the minimum confirm site main circuit breaker and wire size. If both are acceptable, install a boost transformer.
- Check pump-up and recovery time.
 - Turn on the AirStar NEO's power and determine the pump-up time from 0 to 115 PSI.
 - Drain the storage tank to 80 PSI and determine the recovery time from 85 to 115 PSI.
 - If the pump-up or recovery time exceeds the duration listed by the table below, call an authorized dealer for service.

Model	Number of Motors/Heads	Maximum Pump-up Time 0-115 PSI (M:SS)	Maximum Recovery Time 85-115 PSI (M:SS)
AS12NEO-INT	1/1	5:15	1:20
AS22NEO-INT	1/2	2:35	0:40
AS30NEO-INT	2/2	2:41	1:38
AS40NEO-INT (See Note)	2/3	2:54	2:58 1:06
AS50NEO-INT	2/4	2:20	1:27
AS70NEO-INT	3/6	2:30	2:33

Note:

AS40NEO has a single and dual head motor. Recovery time differs depending which is used. The longer recovery time occurs when using a single head motor. The shorter recovery time occurs when using dual head motors.

TANDEM COMPRESSOR SETUP




Figure 4. RJ45 Auxiliary Port Location

Important: Make sure to remove all power to the AirStar NEO before servicing device.

Note: If units to be configured in tandem are missing the RJ45 Termination Resistors, order Tandem Kit P/N 87477.

Tandem Connection:

- 1. Turn the POWER switch on the front of both units to the "OFF" position, and ensure that both units have power removed.
- 2. If necessary, remove the auxiliary port warning label covering the RJ45 connector(s) on each unit.

Important: DO NOT connect the RJ45 cable to the networking port. Make sure the RJ45 cable is inserted into an auxiliary port only.

- 3. Plug one end of the cable into the open RJ45 auxiliary port on the first unit. Make sure that the cable is inserted into the auxiliary port and NOT the networking port.
- 4. Insert the other end of the RJ45 cable into the open auxiliary port of the second unit.
- 5. If not already inserted, insert one RJ45 termination resistor into the remaining RJ45 Auxiliary Port on each device.
- 6. Open the front cover of the unit to be set as the Master device by removing the two screws on the front cover.
- 7. Find the Master/Slave switch on the circuit board, and if necessary move the switch to the right (Master) position.
- 8. Close the front panel and reinstall the two screws to secure the panel.
- 9. Repeat steps 6 through 9 for the Slave device, this time setting the Master/Slave switch to the left (Slave) position.
- 10. Power on each unit. Press the power button on the home screen of the Master device. Make sure the pressure reading on the units is below the cut in pressure and, if necessary, lower the pressure so that all motors on the Master and Slave device start. If this happens, the units are properly working in Tandem mode.

TANDEM COMPRESSOR SETUP





Figure 5. Tandem Compressor Connection

Note: The motor power circuit breaker must be kept in the **ON** position to operate the color LCD touch screen display. See Operating Information on page 15.

All **Airstar NEO** units have a color LCD touch screen display located on the front control box. This display is used to start the compressor and show system operating status. It also serves as an input for controlling and adjusting system operating parameters.

The display shows two screens during normal operation; a Home Screen and a Setting Screen. The Home Screen is used to start and monitor operation of the **Airstar NEO**, while the Setting Screen allows changes to operating parameters.

The screens are comprised operation buttons, navigation buttons and widgets as described below.



Operation Buttons

Standby Button - Home Screen blue button that indicates the system is in the "**Standby**" mode. When pressed, this switch starts the compressor operation.

Running Button - Home Screen Standby button that turns green to indicate the system is in the "**Running**" mode. When pressed, this switch stops the compressor operation and returns to the "**Standby**" mode.

Navigation Buttons - located on the bottom of the screen these buttons allow the user to migrate within a screen by going to the next screen level or to transfer between the Home Screen and a Setting Screen.

Widget - an element of a graphical user interface (gui) that is used to display information during compressor operation. The Home Screen normally shows the Pressure widget while the Voltage and Temperature widgets are accessed by pressing the **Next** Navigation button.

AIRSTAR®NEO AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

TOUCH SCREEN CONTROLS

1. HOME SCREEN

- a. STANDBY BUTTON / PRESSURE SCREEN
 - i. Standby Button
 - Running: Motor(s) and cooler fan(s) run until cut-off pressure is reached (115 PSI default). Motor(s) and cooler fan(s) resume running when falling below cut-in pressure (85 PSI default).
 - Standby: Motor(s) and cooler fan(s) will not run.
 - ii. Pressure Widget Pressure with cut-in/cut-out pressure indicator




b. VOLTAGE / TEMPERATURE SCREEN

i. Voltage Widget - Current line voltage with min/max range indicator.



ii. **Temperature Widget -** Current ambient temperature of room with max temperature limit indicator





a. INFORMATION


- i. Model Air Techniques model number
- ii. SN Unit serial number
- iii. PCB Indicates control board serial number
- iv. Firmware Indicates latest installed firmware and revision
- b. ACCESS 🔀
 - i. User Default setting on startup, this access level should be used when unit is not being serviced by a technician. Set level by pressing RADIO BUTTON.
 - **ii**. **Technician** This access level is used when unit is being serviced by a technician to access all option choices. Set level by pressing RADIO BUTTON.

Note: Access will save on exit by either HOME or BACK BUTTONS

c. PARAMETERS

- i. **Cut-in Pressure** Sets pressure to start recovery. Set pressure by pressing up or down arrows above or below each digit, then press SAVE BUTTON.
- ii. **Cut-out Pressure** Sets pressure to stop recovery. Set pressure by pressing up or down arrows above or below each digit, then press SAVE BUTTON.

Note: Recommended pressure differential range not to exceed: 30 PSI Cut-in pressure range: 70 to 110 PSI Cut-out pressure range: 90 to 130 PSI



- **Operation Mode** Sets mode of operation; Dental Office or CAD/CAM. Set mode by pressing iii. RADIO BUTTON, then press SAVE BUTTON.
 - **Note:** CAD/CAM mode should be used when the unit is going to be used in a high duty cycle situation. Selecting CAD/CAM mode will shorten the activation time for additional compressor heads to assist in pressure recovery.





- **Date** Sets to current date. Set date by pressing up or down arrows above or below each i. digit, then press SAVE BUTTON.
- Time Sets current time. Set time by pressing up or down arrows above or below each digit, ii. then press SAVE BUTTON.
- e. NETWORK
 - Hint: Password "Hint" i.
 - **DHCP:** Indicates DHCP of connected network ii.
 - iii. IP-Address: Indicates IP-Adress of connected network
 - iv. Netmask: Indicates Netmask of connected network
 - Gateway: Indicates Gateway of connected network V.
 - vi. MAC Address: Indicates MAC address of unit
- f. SERVICE

Note: Do not reset clock until all filters have been replaced.

- Service Resets Indicates time remaining before next suggested service. Pressing the i. MAINTENANCE PERFORMED BUTTON will reset clock.
- ii. **Force Run** - When pressed, unit will run motor(s) and cooler fan(s) for thirty (30) seconds.
- q. STATISTICS 1.11
 - i. **On-Time** - Shows time that unit has been powered on (hours)
 - ii. **Run-Time** - Shows time that unit has been running (hours)
 - iii. Duty Cycle Shows percentage of Run-Time over On-Time (%).
- h. ALARM HISTORY Æ


Shows the last forty (40) alarms triggered. Push any listed ALARM BUTTON to get details of alarm, such as suggested tasks and date alarm was triggered.

ALARMS


AirStar NEO checks operation via the Intelligent Monitoring System and alerts the user to problems by displaying Warnings or Errors in the upper left corner of the Home Screen. Warnings notify the user of conditions effecting operation while Errors are critical problems disabling operation. As shown below, explanation of the Warning or Error is expanded by pressing the displayed alert. Also refer to TROUBLESHOOTING, page 18, to correct additional problems.

a. WARNINGS

- i. Line voltage is out of range. Contact technician.
- ii. High duty cycle. Check system and contact technician.
- iii. Over heated motor detected. System operational. Check motor.
- iv. Motor cooled down but disabled. Re-enable motor?
- High room temperature. V.
- vi. Room temperature too low.
- vii. Maintenance required. Contact technician.




Home Screen Showing Warning



b. ERRORS

- Pressure sensor malfunction. Contact technician. i.
- All motors over heated. Contact technician. ii.
- iii. Room temperature above 120°F. Confirm and unit will restart when room has cooled.



Home Screen Showing Error

AIRSTAR® NEO AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

OPERATING INFORMATION

Note a: The motor power circuit breaker must be kept in the ON position and should not be used as a switch for the unit operation.


All **Airstar NEO** units can be operated from either the LCD touch screen or an optional remote switch. The motor **Power** circuit breaker on the face of the compressor control box must be set in the **ON** position whether using the touch screen or the optional remote switch. Since the **Airstar NEO** is designed for continuous operation, the motor **Power** circuit breaker should be kept in the **ON** position. Operate the **Airstar NEO** by performing either the touch screen or remote switch procedure below.


START UP BY TOUCH SCREEN

- Set the motor **Power** circuit breaker in the ON position.
- 2. Observe that the color LCD touch screen display illuminates and depress the blue Standby button.
- 3. Observe that the **Standby** button changes to a green **Running** button and that the unit is running and the **Pressure** widget shows increasing pressure.

START UP BY OPTIONAL REMOTE SWITCH

- 1. Set the motor **Power** circuit breaker to the **ON** position.
- 2. Observe that when in **Standby** with no errors the push button indicator is extinguished.
 - **Note b:** Depending on the site installation, the remote switch can be a single LED 24VDC switch or a Bi-Color LED 6VDC switch. Refer to the tables below for the LED conditions for each switch during operation.
- 3. Depress the push button switch and observe that the associated indicator illuminates as listed for the corresponding switch.





Color LCD Touch Screen Display

24VDC Green Indicator Only (See Note b above.)				
Green LED Condition Switch Position		Condition Description		
None	Out	Standby, No errors		
Solid Green	In	Running, No errors		
Flashing Green – Slow	Out	Standby, Error present		
Green – Fast	In	Running, Error present		

6VDC Bi-Color Green / Yellow Indicators (See Note b above.)				
Bi-Color LED Condition Switch Position		Condition Description		
None	Out	Standby, No errors		
Solid Green	In	Running, No errors		
Flashing Yellow	Out	Standby, Error present		
Alternating Green / Yellow	In	Running, Error present		

TROUBLESHOOTING

Problem	Possible Cause	Possible Solutions
1. Motor does not start.	a. No electric power.	a. Check circuit breaker at main power panel.
	b. Defective circuit breaker.	 b. Circuit breaker needs to be replaced. Call your authorized Air Techniques dealer for service.
2. Motor tries to start, circuit breaker trips off.	a. Voltage too low.lf each compressor head runs separately,but will not run together, the voltage is too low.	a. If the voltage is below the required minimum, a boost transformer must be installed. Call your authorized dealer.
	b. Power supply cable too small.	b. See SITE REQUIREMENTS Table.
	c. Loose electrical connection.	c. Call your authorized dealer for service.
3. Unusual noise.	a. Intake filter(s) not seated correctly.	a. Remove filter(s). Replace if clogged or dirty. When installing, make sure filter chamber is clean and rubber flange on top of filter is pushed all the way down into the metal cylinder.
	b. Intake filter(s) clogged or dirty.	b. Replace filter(s). (PN 89831)
	c. Motor noise.	c. Call your authorized dealer for service.
	d. Air leaks.	d. Call your authorized dealer for service.
	e. Check cooling fans.	e. If fan is loose or broken, call your authorized dealer for service.
4. Compressor cycles but no pressure buildup to 115 psi.	a. Motor noise.	a. Replace filter(s) (PN 89831).
	b. Leak in compressor.	 b. Close the storage tank outlet valve. Check all fittings for leaks. If a leak is found, call your authorized dealer for service.
5. Compressor cycles even when there is no air demand from the operatory.	a. Leak in the compressor.	 a. Disconnect the main power supply. Drain the storage tank slowly until a storage tank pressure of 85 PSI is shown on the pressure display widget. Close the tank outlet valve, turn on the power switch and verify the pump- up time for your model AirStar NEO. Call your authorized Air Techniques dealer if the pump-uptime is incorrect. (See Post Installation Check for pump- up times.)

TROUBLESHOOTING

Problem	Possible Cause	Possible Solutions
	b. Leak in the office air system.	 b. Look at the moisture monitor (see Supplied Components to locate). If it is blue, perform the following: With the AirStar NEO's power switch ON, drain the storage tank to 85 PSI to start the compression cycle. When the cycle shuts off at 115 PSI, close the storage tank outlet valve. Wait 5 minutes and open the stor- age tank outlet valve. If the pressure drops, the air leak is in the office air system or delivery units and not in the AirStar NEO. Call your dealer or plumber for service. If it is pink, see #6 below
6. Moisture monitor is not blue (pink or white).	a. Leak in the office air system. b. Compressor keeps cycling.	 a. If the moisture monitor is pink, there is too much moisture in the system. Call your authorized Air Techniques dealer for service. b. Check the SIZING GUIDE. There may be excessive air demands placed on the AirStar NEO. A larger capacity
7. Operation Button displays Running, tank pressure is below set Cut-In value, motors not running, Touch Screen is unresponsive.	a. Compressor has experienced an electrostatic interference event.	 model may be required. a. Switch main circuit breaker to OFF position for 10 seconds. Switch main circuit breaker to ON position and check for normal operation. If normal operation is not restored, contact your authorized Air Techniques dealer for service.
8. Remote switch is un- responsive. Check for condition #7 as well.	 a. Compressor has experienced an electrostatic interference event. b. Fault in low voltage circuit. 	a. Switch main circuit breaker OFF for 10 seconds. Switch main circuit breaker to ON and check for normal operation. If normal operation is not restored, contact your authorized dealer for service.
9. Touch Screen is unre- sponsive.	 a. Compressor has experienced an electrostatic interference event. b. Fault in Touch Screen assembly. 	 a. Switch main circuit breaker OFF for 10 seconds. Switch main circuit breaker to ON and check for normal operation. If normal operation lf normal operation is not restored, go to step b. b. Calibrate screen by pressing and holding anywhere on the screen for approximately 10 seconds until the calibration prompt screen appears. Follow prompts and touch the three points indicated with a pointed but not sharp object such as a plastic stylus. If normal operation is not possible, contact your authorized Air Techniques dealer for service.

MAINTENANCE

Like all precision products, your **AirStar NEO** requires a certain amount of care on a regularly scheduled basis. A well-organized maintenance program aids dependable equipment operation and reduces problems to a minimum. Routine checks help to detect general overall wear, and replacement of parts can often be made before a problem occurs.

Understanding this, we have established minimum maintenance requirements listed below that include routine inspections and the replacement of filters using preventative maintenance kits available for the specific **AirStar NEO** model. Adherence to this recommended maintenance schedule will ensure that the equipment will continue performing at its best with uninterrupted service.

AirStar NEO also employs an Intelligent Monitoring System, that when prompted by a technician, performs a test for both Pump Up and Recovery Time. This not only makes diagnosing basic errors quick and simple, but also indicates if the problem is with the compressor or the operatory plumbing.

Routine Inspection - Monthly

Clean exterior surfaces.

Check for abnormal noises and air leaks.

Make sure that no flammable, corrosive, or combustible materials are stored in the equipment room (especially in the area around the equipment).

Inspect the Moisture Monitor (Figure 6) for a color change:

Blue indicates that the air in the storage tank is dry.

Pink indicates a high level of humidity is in the storage tank. See TROUBLESHOOTING page 18 to correct this situation.

Routine Inspection - Yearly

Check the Service Indicator on the 5-micron Outlet Filter.

Red indicates that the filter must be replaced P/N 87168.

Green indicates No service is required.



Figure 6. Moisture Monitor Location

Important: In dusty environments, the Intake Filter, PN 89831, may need to be changed more often than once a year.

Always dispose of the removed filter in accordance with local codes.

Filter Replacement - Yearly

Refer to Figure 7 for the location of filters to be replaced using the preventative maintenance kit for the specific **AirStar NEO** mode listed below. Replace the filters and associated O-rings in accordance with the instructions provided with the kit.

AIR STAR[®] NEO

ational

AirStar NEO Model		AS12NEO-INT	AS22NEO-INT AS30NEO-INT	AS40NEO-INT	AS50NEO-INT	AS70NEO-INT
Kit Part No		87351	87352	87355	87353	87354
Component	Part No.	Qty	Qty	Qty	Qty	Qty
Compressor Air Intake Filter	89938R	1	2	3	4	6
Top Membrane Filter	87171	1	1	1	1	2
Bottom Membrane Filter	87367	1	1	1	1	2
Bottom Membrane Filter Bowl	87362	1	1	1	1	2
Top Cover O-ring	87368	1	1	1	1	2
Filter Bowl O-ring	87369	1	1	1	1	2

Preventive Maintenance Kits Supplied Components




Figure 7. AirStar NEO Filter Location

REPLACEMENT PARTS

Description	Part No.
5 Micron Replacement Filter	87168
Filter Replacement Kits (Kit parts differ for AirStor NEO models. See previous page for components supplied by each kit listed below.)	
AirStar Model	Kit Part No.
AS12NEO-INT	87351
AS22NEO-INT	87352
AS30NEO-INT	07352
AS40NEO-INT	87355
AS50NEO-INT	87353
AS70NEO-INT	87354
Main PCB Assembly Replacement Kits (Kits differ for AirStor NEO models as listed below.)	
AirStar Model	Kit Part No.
AS12NEO-INT	85205-1
AS22NEO-INT	85205-3
AS30NEO-INT	85205-4
AS40NEO-INT	85205-5
AS50NEO-INT	85205-6
AS70NEO-INT	85205-7

AIRSTAR®NEO AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

OPTIONAL ACCESSORIES

Description	Model	Part Number
	AS12NEO-INT	85491
	AS22NEO-INT, AS30NEO-INT	85492
REMOTE AIR INTAKE KIT	AS40NEO-INT	87361
-	AS50NEO-INT	85493
	AS70NEO-INT	85494
REMOTE CONTROL PANELS w/24 V switches (See Note)		
1-Switch Plate Kit		53111
2-Switch Plate Kit	For all AirStar NEOs	53251
3-Switch Plate Kit 4-Switch Plate Kit		53250
		53133

Note: To meet facility requirements, the 24 V remote switch provided with Remote Control Panels can be replaced by the 6VDC switch (P/N 53202-1) provided in accessory kit

AIRSTAR[®] NEO AS12NEO-INT, AS22NEO-INT, AS30NEO-INT, AS40NEO-INT, AS50NEO-INT & AS70NEO-INT

PRODUCT SPECIFICATIONS

Mode	əl	AS12NEO-INT	AS22NEO-INT	AS30NEO-INT	AS40NEO-INT	AS50NEO-INT	AS70NEO-INT
Input Voltage Phase		1	1	1	1	1	1
System Power HP (kW)		1.6 (1.2)	1.6 (1.2)	2.0 (1.5)	2.6 (1.95)	3.2 (2.4)	4.8 (3.6)
Nominal Supply Voltage VAC		220	220	220	220	220	220
Frequency Hz		5.0	5.0	5.0	5.0	5.0	5.0
Maximum Current Amps		15	8	8	12	16	24
Maximum Simultaneous Users	Air	3	3	4	5	7	10
System Output Flow Rat at 80 PSI CFM	e	5.0	5.0	5.0	7.5	10.0	15.0
Maximum Pump-up Time 0-115 PSI (M:SS)	•	2:35	2:35	2:41	2:54	2:30	2:30
Maximum Recovery Time 85-115 PSI (M:SS)	9	0:40	0:40	1:38	2:58 / 1:06 See Note 1	1:27	2:30
Tank Size US Gal. (ft ³)		9.75 (1.3)	9.75 (1.3)	9.75 (1.3)	16 (2.1)	16 (2.1)	27 (3.6)
Shipping Weight lbs. (Approximate)		185	185	230	270	285	395
	w	26.50	26.50	26.50	30.75	30.75	48.00
Dimensions (in. See Note 2)	н	29.50	29.50	29.50	32.50	32.50	32.50
	D	20.00	20.00	20.00	21.00	21.00	21.00

Notes:

- 1. AS40NEO-INT has a single and dual head motor. Recovery time differs depending which is used. The longer recovery time occurs when using a single head motor. The shorter recovery time occurs when using dual head motors.
- 2. Height measured without leveling feet.

Each **AirStar NEO-INT** is warranted to be free from defects in material and workmanship from the date of installation for a period of 2 years (24 months) on complete unit.

All part and component returns and replacement equipment require a Return Materials Authorization (RMA). Returns must be received within three months of the RMA issue date and in appropriate packaging to prevent shipping damage. In case of advanced replacement, products shall be returned in the original packaging. Items returned without an RMA, or included with other products for which an RMA has been issued, will be returned to the customer at the discretion of Air Techniques, Inc.; the return shipping is the customer's responsibility.

Any item returned under warranty, will be repaired or replaced at our option at no charge provided that our inspection confirms it to be defective. Air Techniques, Inc. is not liable for indirect or consequential damages or loss of any nature in connection with this equipment. Dealer labor, shipping and handling charges are not covered by this warranty.

Warranty credit will not be applied to product returns that exhibit damage due to shipping, misuse, careless handling, and improper installation by dealers, or repairs by unauthorized personnel. Credit, or partial credit, will not be issued until products/parts have been received and assessed. If, after the evaluation it is determined that there is no-fault found and the unit is working properly, a credit will not be issued. Warranty is void if product is installed incorrectly or installed or serviced by anyone other than an authorized Air Techniques' dealer or service personnel.

This warranty is in lieu of all other warranties expressed or implied. No representative or person is authorized to assume for us any liability in connection with the sale of our equipment.

ON-LINE WARRANTY REGISTRATION

Quickly and easily register your new **AirStar NEO** on-line. Just have your product model and serial numbers available. Then go to the Air Techniques web site, **www.airtechniques.com/dental**, click the **warranty registration** link and complete the registration form. This on-line registration ensures a record for the warranty period and helps us keep you informed of product updates and other valuable information.



NOTES

For over 50 years, Air Techniques has been a leading innovator and manufacturer of dental products. Our priority is ensuring complete satisfaction by manufacturing reliable products and providing excellent customer and technical support. Whether the need is digital imaging, utility room equipment or merchandise, Air Techniques can provide the solution via our network of authorized professional dealers. Proudly designed, tested and manufactured in the U.S., our products are helping dental professionals take their practices to the next level.

Air Techniques' family of quality products for the dental professional include:

Digital Imaging

- Digital Radiography
- Intraoral Camera
- Caries Detection Aid
- Intraoral X-ray
- Panoramic X-ray
- Film Processors

□ Utility Room

- Dry Vacuums
- Wet Vacuums
- Air Compressors
- Amalgam Separator
- Utility Accessories
- Utility Packages

Merchandise

- Surface Disinfectant
- Enzymatic Cleaner
- Hand Sanitizer and Lotion
- Waterline Cleaner
- Evacuation System Cleaner
- Imaging Accessories
- Chemistry
- Processor Accessories



Air Techniques, Inc.

1295 Walt Whitman Road Melville, New York, USA 11747- 3062

www.airtechniques.com



Australian Sponsor

Emergo Australia Level 20 Tower II, Darling Park, 201 Sussex Street, Sydney, NSW 2000. Australia



AirStar is a registered trademark of Air Techniques, Inc. © 2015 Air Techniques, Inc. • P/N 87199INT, Rev. G • November 2020

				2				
		17	ln.			11 In.		
	11 In.				8½ In.			
		81/."	 x 11" Bo		8½" x 5½" Book			
В	8½ In.					11 ln.		
	11 in. 14 in.			17 In		1. Binding Edge		
			Print Sin Print Do	gle Side uble Side		No Hole Punch 3-Hole @ Binding Edge		
	Applicati	ion File Typ	e:			Additional Options:		
		Design F (for viewin	g)	Quark MS Wo		Print in Color		
		elDraw	Card Stock					
	Air Techniques Storage Location: Stored by document part number in one of the net- work release drive directories checked below.					Saddle Stitch / Fold (Staple Binding).		
	Manuals Instructions				UV Coat Both Sides			
A	Finished Document Print Requirements					Laminate		
	Doc size:					3-Hole Binding		
	Total sheets:					Single hole punch		
		uirements	Weight	Brightness	Finish	left corner front side		
		andard ustom				Spiral Bound Booklets		
		ack & White	Wire-O Booklets (Metal Coil Binding)					

DATE	REV	REVISION RECORD	AUTH	DWN	ск
			SFUL		

1

Comments:

Artwork print file provided by Air Techniques

Important:

Make sure to print only the latest revision from the network release drive using the original document file for best printing results. Never print scanned copies from the (engscan network drive).

PRAWN equipped for life®					
MATERIAL SEE FE A HS	TITLE				
FINISH SEE FE A HG					
DATE	size 5	PART NO.		REV	

1

В

Α